

# FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO  
NRG Texas Power LLC

AUTHORIZING THE OPERATION OF  
T H Wharton Electric Generating Station  
Fossil Fuel Electric Power Generation

LOCATED AT  
Harris County, Texas  
Latitude 29° 56' 16" Longitude 95° 31' 56"  
Regulated Entity Number: RN100542885

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: 077 Issuance Date: \_\_\_\_\_

\_\_\_\_\_  
For the Commission

## Table of Contents

Section	Page
General Terms and Conditions .....	1
Special Terms and Conditions: .....	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements .....	8
New Source Review Authorization Requirements .....	9
Compliance Requirements.....	9
Protection of Stratospheric Ozone .....	11
Temporary Fuel Shortages (30 TAC § 112.15) .....	11
Permit Location .....	11
Permit Shield (30 TAC § 122.148) .....	11
Acid Rain Unit Exemptions .....	12
Cross-State Air Pollution Rule (CSAPR) Trading Program Requirements .....	12
Cross-State Air Pollution Rule (CSAPR) Trading Program Unit Exemptions .....	18
Attachments .....	19
Applicable Requirements Summary.....	20
Additional Monitoring Requirements .....	33
Permit Shield.....	45
New Source Review Authorization References .....	50
Appendix A.....	57
Acronym List .....	58

## **General Terms and Conditions**

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

## **Special Terms and Conditions:**

### **Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting**

1. Permit holder shall comply with the following requirements:
  - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
  - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
  - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
  - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
  - E. Emission units subject to 40 CFR Part 63, Subpart ZZZZ and DDDDD as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113,

Subchapter C, § 113.1090 and 113.1130 which incorporates the 40 CFR Part 63 Subpart by reference.

- F. For the purpose of generating emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 1 (Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
- (i) Title 30 TAC § 101.302 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.303 (relating to Emission Reduction Credit Generation Certification)
  - (iii) Title 30 TAC § 101.304 (relating to Mobile Emission Reduction Credit Generation and Certification)
  - (iv) Title 30 TAC § 101.309 (relating to Emission Credit Banking and Trading)
  - (v) The terms and conditions by which the emission limits are established to generate the reduction credit are applicable requirements of this permit
- G. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 2 (Emissions Banking and Trading of Allowances) Requirements for an electric generating facility authorized under 30 TAC Chapter 116, Subchapter I:
- (i) Title 30 TAC § 101.332 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.333 (relating to Allocation of Allowances)
  - (iii) Title 30 TAC § 101.334 (relating to Allowance Deductions)
  - (iv) Title 30 TAC § 101.335 (relating to Allowance Banking and Trading)
  - (v) Title 30 TAC § 101.336 (relating to Emission Monitoring and Compliance Demonstration and Reporting)
  - (vi) The terms and conditions by which the emission limits are established to meet the quantity of allowances for the electric generating facility are applicable requirements of this permit
- H. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emission Cap and Trade Program) Requirements:
- (i) Title 30 TAC § 101.352 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.353 (relating to Allocation of Allowances)
  - (iii) Title 30 TAC § 101.354 (relating to Allowance Deductions)
  - (iv) Title 30 TAC § 101.356 (relating to Allowance Banking and Trading)
  - (v) Title 30 TAC § 101.359 (relating to Reporting)
  - (vi) Title 30 TAC § 101.360 (relating to Level of Activity Certification)

- (vii) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit
- I. For the purpose of generating discrete emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 4 (Discrete Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
  - (i) Title 30 TAC § 101.372 (relating to General Provisions)
  - (ii) Title 30 TAC § 101.373 (relating to Discrete Emission Reduction Credit Generation and Certification)
  - (iii) Title 30 TAC § 101.374 (relating to Mobile Discrete Emission Reduction Credit Generation and Certification)
  - (iv) Title 30 TAC § 101.378 (relating to Discrete Emission Credit Banking and Trading)
  - (v) The terms and conditions by which the emission limits are established to generate the discrete reduction credit are applicable requirements of this permit
- 2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
  - A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
  - B. Title 30 TAC § 101.3 (relating to Circumvention)
  - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
  - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
  - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
  - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
  - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
  - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
  - I. Title 30 TAC § 101.222 (relating to Demonstrations)
  - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
- 3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
  - A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity

averaged over a six minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:

- (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(1)(E)
- (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
- (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the "Applicable Requirements Summary" attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:
  - (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
  - (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
  - (3) Records of all observations shall be maintained.
  - (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet

prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(5) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
  - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.
  - (2) Records of all observations shall be maintained.

(3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A).
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

C. For visible emissions from all other sources not specified in 30 TAC § 111.111(a)(1), (4), or (7); the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(8)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(8)(B)(i) or (ii)
- (iii) For a source subject to 30 TAC § 111.111(a)(8)(A), complying with 30 TAC § 111.111(a)(8)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO<sub>x</sub>, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:



- (1) An observation of visible emissions from a source which is required to comply with 30 TAC § 111.111(a)(8)(A) shall be conducted at least once during each calendar quarter unless the source is not operating for the entire quarter.
  - (2) Records of all observations shall be maintained.
  - (3) Visible emissions observations of sources operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of sources operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each source in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each source during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
  - (4) Compliance Certification:
    - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(8) and (a)(8)(A)
    - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(8)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
- D. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- E. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).

- F. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
  - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
  - (ii) Sources with an effective stack height ( $h_e$ ) less than the standard effective stack height ( $H_e$ ), must reduce the allowable emission level by multiplying it by  $[h_e/H_e]^2$  as required in 30 TAC § 111.151(b)
  - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
- G. Outdoor burning, as stated in 30 TAC § 111.201, shall not be authorized unless the following requirements are satisfied:
  - (i) Title 30 TAC § 111.205 (relating to Exception for Fire Training)
  - (ii) Title 30 TAC § 111.207 (relating to Exception for Recreation, Ceremony, Cooking, and Warmth)
  - (iii) Title 30 TAC § 111.209 (relating to Exception for Disposal Fires)
  - (iv) Title 30 TAC § 111.219 (relating to General Requirements for Allowable Outdoor Burning)
  - (v) Title 30 TAC § 111.221 (relating to Responsibility for Consequences of Outdoor Burning)
- 4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: Storage of Volatile Organic Compounds, the permit holder shall comply with the requirements of 30 TAC § 115.112(e)(1).
- 5. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.

#### **Additional Monitoring Requirements**

- 6. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time or minimum frequency specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

## **New Source Review Authorization Requirements**

7. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule (including the permits by rule identified in the PBR Supplemental Tables in the application), standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
  - A. Are incorporated by reference into this permit as applicable requirements
  - B. Shall be located with this operating permit
  - C. Are not eligible for a permit shield
8. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
9. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
10. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
  - A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
  - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
  - C. Requirements of the non-rule Air Quality Standard Permit for Pollution Control Projects

## **Compliance Requirements**

11. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
12. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:

- A. The permit holder shall comply with the compliance schedules and submit written notification to the Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
  - (i) For electric utilities in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9120
- 13. Use of Emission Credits to comply with applicable requirements:
  - A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
    - (i) Title 30 TAC Chapter 115
    - (ii) Title 30 TAC Chapter 117
    - (iii) Offsets for Title 30 TAC Chapter 116
  - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
    - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)
    - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
    - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
    - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
    - (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)
- 14. Use of Discrete Emission Credits to comply with the applicable requirements:
  - A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
    - (i) Title 30 TAC Chapter 115
    - (ii) Title 30 TAC Chapter 117
    - (iii) If applicable, offsets for Title 30 TAC Chapter 116
    - (iv) Temporarily exceed state NSR permit allowables
  - B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
    - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)

- (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
- (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
- (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
- (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

### **Protection of Stratospheric Ozone**

15. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
  - A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.
  - B. The permit holder shall comply with 40 CFR Part 82, Subpart H related to Halon Emissions Reduction requirements as specified in 40 CFR § 82.250 - § 82.270 and the applicable Part 82 Appendices.

### **Temporary Fuel Shortages (30 TAC § 112.15)**

16. The permit holder shall comply with the following 30 TAC Chapter 112 requirements:
  - A. Title 30 TAC § 112.15 (relating to Temporary Fuel Shortage Plan Filing Requirements)
  - B. Title 30 TAC § 112.16(a), (a)(1), and (a)(2)(B) - (C) (relating to Temporary Fuel Shortage Plan Operating Requirements)
  - C. Title 30 TAC § 112.17 (relating to Temporary Fuel Shortage Plan Notification Procedures)
  - D. Title 30 TAC § 112.18 (relating to Temporary Fuel Shortage Plan Reporting Requirements)

### **Permit Location**

17. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

### **Permit Shield (30 TAC § 122.148)**

18. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with

the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

### **Acid Rain Unit Exemptions**

19. As reference only information, Unit 2 (identified in the Certificate of Representation as unit THW2) has received an acid rain unit exemption and is not incorporated into an Acid Rain Permit.

### **Cross-State Air Pollution Rule (CSAPR) Trading Program Requirements**

20. For units GT31, GT32, GT33, GT34, GT41, GT42, GT43, GT44, GT51, GT52, GT53, GT54, GT55, and GT56 (identified in the Certificate of Representation as units 31, 32, 33, 34, 41, 42, 43, 44, 51, 52, 53, 54, 55, and 56), located at the site identified by ORIS/Facility code 3469, the designated representative and the owner or operator, as applicable, shall comply with the following CSAPR requirements.

#### **A. General Requirements**

- (i) The owners and operators of the CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall operate the source and the unit in compliance with the requirements of the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program and all other applicable State and federal requirements.
- (ii) The owners and operators of the CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall comply with the requirements of 40 CFR Part 97, Subpart EEEEE for CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program, and with the General Terms and Conditions of the Federal Operating Permit (FOP) that incorporates the CSAPR requirements.

#### **B. Description of CSAPR Monitoring Provisions**

- (i) The CSAPR subject unit(s), and the unit-specific monitoring provisions at this source, are identified in the following paragraph(s). These unit(s) are subject to the requirements for the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program.
  - (1) For unit(s) GT51, GT52, GT53, GT54, GT55, and GT56, the owners and operators shall comply with the Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR § 75.19 for NO<sub>x</sub> and heat input.
  - (2) For unit(s) GT31, GT32, GT33, GT34, GT41, GT42, GT43, and GT44, the owners and operators shall comply with the EPA-approved alternative monitoring system requirements pursuant to 40 CFR Part 75, Subpart E for NO<sub>x</sub> and heat input.
- (ii) The above description of the monitoring used by a unit does not change, create an exemption from, or otherwise affect the monitoring, recordkeeping, and

reporting requirements applicable to the unit under 40 CFR §§ 97.830 through 97.835 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program). The monitoring, recordkeeping and reporting requirements applicable to each unit are included below in the standard conditions for the applicable CSAPR trading program.

- (iii) Owners and operators must submit to the Administrator a monitoring plan for each unit in accordance with 40 CFR §§ 75.53, 75.62 and 75.73, as applicable. The monitoring plan for each unit is available at the EPA's website at <https://www.epa.gov/airmarkets/clean-air-markets-monitoring-plans-part-75-sources>.
- (iv) Owners and operators that want to use an alternative monitoring system must submit to the Administrator a petition requesting approval of the alternative monitoring system in accordance with 40 CFR Part 75, Subpart E and 40 CFR § 75.66 and § 97.835 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program). The Administrator's response approving or disapproving any petition for an alternative monitoring system is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
- (v) Owners and operators that want to use an alternative to any monitoring, recordkeeping, or reporting requirement under 40 CFR §§ 97.830 through 97.834 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program) must submit to the Administrator a petition requesting approval of the alternative in accordance with 40 CFR § 75.66 and § 97.835 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program). The Administrator's response approving or disapproving any petition for an alternative to a monitoring, recordkeeping, or reporting requirement is available on the EPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
- (vi) The descriptions of monitoring applicable to the unit(s) included above meet the requirement of 40 CFR §§ 97.830 through 97.834 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program), and therefore procedures for minor permit revisions, in accordance with 30 TAC § 122.217, may be used to add or change this unit's monitoring system description.

21. CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program Requirements (40 CFR § 97.806)

A. Designated representative requirements

- (i) The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR §§ 97.813 through 97.818.

B. Emissions monitoring, reporting, and recordkeeping requirements

- (i) The owners and operators, and the designated representative, of each CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR § 97.830 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), § 97.831 (initial monitoring system certification and recertification procedures), § 97.832 (monitoring system out-of-control periods), § 97.833 (notifications concerning monitoring), § 97.834 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and §

97.835 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).

- (ii) The emissions data determined in accordance with 40 CFR § 97.830 through § 97.835 and any other credible evidence shall be used to calculate allocations of CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances under 40 CFR §§ 97.811(a)(2) and (b) and § 97.812 and to determine compliance with the CSAPR NO<sub>x</sub> Ozone Season Group 2 emissions limitation and assurance provisions under paragraph C. below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR §§ 97.830 through 97.835 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

C. NO<sub>x</sub> emissions requirements

(i) CSAPR NO<sub>x</sub> Ozone Season Group 2 emissions limitation

- (1) As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall hold, in the source's compliance account, CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances available for deduction for such control period under 40 CFR § 97.824(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for such control period from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at the source.
- (2) If total NO<sub>x</sub> emissions during a control period in a given year from the CSAPR NO<sub>x</sub> Ozone Season Group 2 units at a CSAPR NO<sub>x</sub> Ozone Season Group 2 source are in excess of the CSAPR NO<sub>x</sub> Ozone Season Group 2 emissions limitation set forth in paragraph C.(i)(1) above, then:
  - (a) The owners and operators of the source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall hold the CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances required for deduction under 40 CFR § 97.824(d); and
  - (b) The owners and operators of the source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart EEEEE and the Clean Air Act.

(ii) CSAPR NO<sub>x</sub> Ozone Season Group 2 assurance provisions

- (1) If total NO<sub>x</sub> emissions during a control period in a given year from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO<sub>x</sub> emissions during such control period



exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances available for deduction for such control period under 40 CFR § 97.825(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR § 97.825(b), of multiplying -

- (a) The quotient of the amount by which the common designated representative's share of such NO<sub>x</sub> emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such NO<sub>x</sub> emissions exceeds the respective common designated representative's assurance level; and
  - (b) The amount by which total NO<sub>x</sub> emissions from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state for such control period exceed the state assurance level.
- (2) The owners and operators shall hold the CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances required under paragraph C.(ii)(1) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
- (3) Total NO<sub>x</sub> emissions from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state during a control period in a given year exceed the state assurance level if such total NO<sub>x</sub> emissions exceed the sum, for such control period, of the state NO<sub>x</sub> Ozone Season Group 2 trading budget under 40 CFR § 97.810(a) and the state's variability limit under 40 CFR § 97.810(b).
- (4) It shall not be a violation of 40 CFR Part 97, Subpart EEEEE or of the Clean Air Act if total NO<sub>x</sub> emissions from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state during a control period exceed the state assurance level or if a common designated representative's share of total NO<sub>x</sub> emissions from the CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state during a control period exceeds the common designated representative's assurance level.
- (5) To the extent the owners and operators fail to hold CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances for a control period in a given year in accordance with paragraphs C.(ii)(1) through (3) above,
  - (a) The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
  - (b) Each CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance that the owners and operators fail to hold for such control period in

accordance with paragraphs C.(ii)(1) through (3) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart EEEEE and the Clean Air Act.

(iii) Compliance periods

- (1) A CSAPR NO<sub>x</sub> Ozone Season Group 2 unit shall be subject to the requirements under paragraph C.(i) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR § 97.830(b) and for each control period thereafter.
- (2) A CSAPR NO<sub>x</sub> Ozone Season Group 2 unit shall be subject to the requirements under paragraph C.(ii) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR § 97.830(b) and for each control period thereafter.

(iv) Vintage of allowances held for compliance

- (1) A CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance held for compliance with the requirements under paragraph C.(i)(1) above for a control period in a given year must be a CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance that was allocated for such control period or a control period in a prior year.
- (2) A CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance held for compliance with the requirements under paragraphs C.(i)(2)(a) and (ii)(1) through (3) above for a control period in a given year must be a CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.

(v) Allowance Management System requirements. Each CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart EEEEE.

(vi) Limited authorization. A CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance is a limited authorization to emit one ton of NO<sub>x</sub> during the control period in one year. Such authorization is limited in its use and duration as follows:

- (1) Such authorization shall only be used in accordance with the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program; and
- (2) Notwithstanding any other provision of 40 CFR Part 97, Subpart EEEEE, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.

(vii) Property right. A CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance does not constitute a property right.

D. FOP revision requirements

- (i) No FOP revision shall be required for any allocation, holding, deduction, or transfer of CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances in accordance with 40 CFR Part 97, Subpart EEEEE.
- (ii) This FOP incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR §§ 97.830 through 97.835, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, subpart H), an excepted monitoring system (pursuant to 40 CFR Part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR § 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, subpart E). Therefore the Description of CSAPR Monitoring Provisions for CSAPR subject unit(s) may be added to, or changed, in this FOP using procedures for minor permit revisions in accordance with 30 TAC § 122.217.

E. Additional recordkeeping and reporting requirements

- (i) Unless otherwise provided, the owners and operators of each CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
  - (1) The certificate of representation under 40 CFR § 97.816 for the designated representative for the source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR § 97.816 changing the designated representative.
  - (2) All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart EEEEE.
  - (3) Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program.
- (ii) The designated representative of a CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall make all submissions required under the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program, except as provided in 40 CFR § 97.818. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under 30 TAC § 122.165.

F. Liability

- (i) Any provision of the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program that applies to a CSAPR NO<sub>x</sub> Ozone Season Group 2 source or the designated representative of a CSAPR NO<sub>x</sub> Ozone Season Group 2 source shall also apply

to the owners and operators of such source and of the CSAPR NO<sub>x</sub> Ozone Season Group 2 units at the source.

- (ii) Any provision of the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program that applies to a CSAPR NO<sub>x</sub> Ozone Season Group 2 unit or the designated representative of a CSAPR NO<sub>x</sub> Ozone Season Group 2 unit shall also apply to the owners and operators of such unit.

G. Effect on other authorities

- (i) No provision of the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program or exemption under 40 CFR § 97.805 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR NO<sub>x</sub> Ozone Season Group 2 source or CSAPR NO<sub>x</sub> Ozone Season Group 2 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

**Cross-State Air Pollution Rule (CSAPR) Trading Program Unit Exemptions**

- 22. As reference-only information, unit 2 (identified in the Certificate of Representation as unit THW2 in the EPA Retired Unit Exemption form) has received a CSAPR retired unit exemption under 40 CFR Part 97 (CSAPR NO<sub>x</sub> and SO<sub>2</sub> Trading Programs) and is not subject to CSAPR Requirements.

## **Attachments**

**Applicable Requirements Summary**

**Additional Monitoring Requirements**

**Permit Shield**

**New Source Review Authorization References**

### **Applicable Requirements Summary**

<b>Unit Summary .....</b>	<b>21</b>
---------------------------	-----------

<b>Applicable Requirements Summary .....</b>	<b>24</b>
--	-----------

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
GH1	PROCESS HEATERS/FURNACES	N/A	63DDDDD-1	40 CFR Part 63, Subpart DDDDD	No changing attributes.
GRPGT1	STATIONARY TURBINES	GT31, GT32, GT33, GT34, GT41, GT42, GT43, GT44	R7UT-1	30 TAC Chapter 117, Utility Electric Generation	No changing attributes.
GRPGT1-LOV	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	GT31-LOV, GT32-LOV, GT33-LOV, GT34-LOV, GT41-LOV, GT42-LOV, GT43-LOV, GT44-LOV	R1111-2	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPGT2	STATIONARY TURBINES	GT51, GT52, GT53, GT54, GT55, GT56	R7UT-1	30 TAC Chapter 117, Utility Electric Generation	Fuel Type = Firing natural gas only.
GRPGT2	STATIONARY TURBINES	GT51, GT52, GT53, GT54, GT55, GT56	R7UT-2	30 TAC Chapter 117, Utility Electric Generation	Fuel Type = Firing fuel oil only.
GRPGT2-LOV	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	GT51-LOV, GT52-LOV, GT53-LOV, GT54-LOV, GT55-LOV, GT56-LOV	R1111-2	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPGTSTK	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	THWGT1, THWGT31, THWGT32, THWGT33, THWGT34, THWGT41, THWGT42, THWGT43, THWGT44, THWGT51, THWGT52, THWGT53, THWGT54, THWGT55, THWGT56	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPTANK1	STORAGE TANKS/VESSELS	A-107-1, A-107-2, A- 123, A-124, A-125, A- 126, A-127, A-128, A- 129, A-130, A-131	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPTANK2	STORAGE TANKS/VESSELS	A-105-1, A-105-2, A- 106-1, A-106-2, A-132, A-133, A-134, A-135, A-	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.

### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		136, A-137, A-138, A-139			
GRPTANK3	STORAGE TANKS/VESSELS	A-206, B-207	R5112-1	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GT1	STATIONARY TURBINES	N/A	R7UT-1	30 TAC Chapter 117, Utility Electric Generation	No changing attributes.
GT1-LOV	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-2	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GT1C	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-2	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GT1C	SRIC ENGINES	N/A	63ZZZZ-01	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GT1E	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-2	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GT1E	SRIC ENGINES	N/A	63ZZZZ-01	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
MCT3	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-1	30 TAC Chapter 111, Visible Emissions	No changing attributes.
S1	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	N/A	R5131-1	30 TAC Chapter 115, Water Separation	No changing attributes.
T120	STORAGE TANKS/VESSELS	N/A	R5112-2	30 TAC Chapter 115, Storage of VOCs	No changing attributes.



### Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
THWUNLOAD	LOADING/UNLOADING OPERATIONS	N/A	R5212-1	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
U3ST-LOV	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-2	30 TAC Chapter 111, Visible Emissions	No changing attributes.
U4ST-LOV	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-2	30 TAC Chapter 111, Visible Emissions	No changing attributes.

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements  (30 TAC § 122.144)	Reporting Requirements  (30 TAC § 122.145)
GH1	EU	63DDDDD-1	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7500(a)(1)-Table 3.2 § 63.7500(a)(1) § 63.7500(a)(3) § 63.7500(e) § 63.7505(a) § 63.7540(a) [G]§ 63.7540(a)(10) § 63.7540(a)(11) § 63.7540(a)(13)	A new or existing boiler or process heater with heat input capacity of less than 10 million Btu per hour, but greater than 5 million Btu per hour, in a unit designed to burn gas 1 must conduct a tune-up of the boiler or process heater biennially as specified in § 63.7540.	§ 63.7515(d) [G]§ 63.7521(f) [G]§ 63.7521(g) § 63.7521(h) § 63.7521(i) § 63.7530(g) § 63.7540(a) [G]§ 63.7540(a)(10) [G]§ 63.7540(c)	§ 63.7555(a) § 63.7555(a)(1) § 63.7555(a)(2) § 63.7555(g) § 63.7555(h) § 63.7560(a) § 63.7560(b) § 63.7560(c)	[G]§ 63.7521(g) § 63.7530(e) § 63.7530(f) § 63.7545(a) § 63.7545(b) § 63.7545(c) [G]§ 63.7545(e) [G]§ 63.7545(f) § 63.7550(a) [G]§ 63.7550(b) [G]§ 63.7550(c) [G]§ 63.7550(h)
GRPGT1	EU	R7UT-1	CO	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(1) § 117.1210(b) § 117.1210(b)(1)(A)	No person shall allow the discharge into the atmosphere from any unit subject to the NO <sub>x</sub> emission specifications specified in subsection (a) of this section, carbon monoxide (CO) emissions in excess of 400 parts per million by volume (ppmv) at 3.0% oxygen (O <sub>2</sub> ), dry, or alternatively, 0.30 lb/MMBtu heat input for gas-fired stationary gas turbines.	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(b) § 117.1240(i) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRPGT1	EU	R7UT-1	NO <sub>x</sub>	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(a)(3) [G]§ 117.1203(c) § 117.1210(c)(3) § 117.1220(a) § 117.1220(b) [G]§ 117.1220(c) § 117.1220(d) § 117.1220(e) § 117.1220(i) § 117.1220(j) § 117.1220(k)	Emission specifications for the Mass Emission Cap and Trade Program. The owner or operator of each stationary gas turbine (including duct burners used in turbine exhaust ducts), shall ensure that emissions of nitrogen oxides (NO <sub>x</sub> ) do not exceed 0.032, in lb/MMBtu heat input, on the	§ 117.1220(d) [G]§ 117.1220(e)(3) § 117.1220(h) § 117.1220(k) § 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1235(c) § 117.1235(d) § 117.1235(d)(1) § 117.1235(d)(2)	§ 117.1220(f) § 117.1245(a) [G]§ 117.1245(e)	[G]§ 117.1203(c) § 117.1220(g) § 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1245(b)(2) [G]§ 117.1245(c) § 117.1245(d) § 117.1245(d)(2) § 117.1245(d)(3) § 117.1245(d)(4)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements  (30 TAC § 122.144)	Reporting Requirements  (30 TAC § 122.145)
					§ 117.1220(l) § 117.1220(m) § 117.1240(l) § 117.1240(l)(2) § 117.1240(o) § 117.1240(o)(3)	basis of daily and 30-day averaging periods as specified in §117.1220 of this title, and as specified in the mass emissions cap and trade program of Chapter 101, Subchapter H, Division 3 of this title.	§ 117.1235(d)(3) § 117.1240(a) [G]§ 117.1240(g) § 117.1240(i) § 117.1240(n) § 117.1240(o)(1) § 117.8110(b) § 117.8110(b)(1) [G]§ 117.8110(b)(1)(A) § 117.8110(b)(1)(B) § 117.8110(b)(2) [G]§ 117.8110(b)(3)		§ 117.1245(d)(5) [G]§ 117.1254(b) § 117.1254(c) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRPGT1-LOV	EP	R1111-2	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRPGT2	EU	R7UT-1	CO	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(1) § 117.1210(b) § 117.1210(b)(1)(A)	No person shall allow the discharge into the atmosphere from any unit subject to the NO <sub>x</sub> emission specifications specified in subsection (a) of this section, carbon monoxide (CO) emissions in excess of 400 parts per million by volume (ppmv) at 3.0% oxygen (O <sub>2</sub> ), dry, or alternatively, 0.30 lb/MMBtu heat input for gas-fired	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(b) § 117.1240(i) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements  (30 TAC § 122.144)	Reporting Requirements  (30 TAC § 122.145)
						stationary gas turbines.			[G]§ 117.8010(7) [G]§ 117.8010(8)
GRPGT2	EU	R7UT-1	NO <sub>x</sub>	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(a)(3) [G]§ 117.1203(c) § 117.1210(c)(3) § 117.1220(a) § 117.1220(b) [G]§ 117.1220(c) § 117.1220(d) § 117.1220(e) § 117.1220(i) § 117.1220(j) § 117.1220(k) § 117.1220(l) § 117.1220(m) § 117.1240(l) § 117.1240(l)(2) § 117.1240(o) § 117.1240(o)(3)	Emission specifications for the Mass Emission Cap and Trade Program. The owner or operator of each stationary gas turbine (including duct burners used in turbine exhaust ducts), shall ensure that emissions of nitrogen oxides (NO <sub>x</sub> ) do not exceed 0.032, in lb/MMBtu heat input, on the basis of daily and 30-day averaging periods as specified in §117.1220 of this title, and as specified in the mass emissions cap and trade program of Chapter 101, Subchapter H, Division 3 of this title.	§ 117.1220(d) § 117.1220(e)(2) § 117.1220(h) § 117.1220(k) § 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(a) § 117.1240(e) § 117.1240(e)(1) § 117.1240(i) § 117.1240(n) § 117.1240(o)(1) [G]§ 117.1240(o)(2)	§ 117.1220(f) § 117.1245(a) [G]§ 117.1245(e)	[G]§ 117.1203(c) § 117.1220(g) § 117.1235(b) § 117.1245(b) § 117.1245(b)(1) [G]§ 117.1254(b) § 117.1254(c) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRPGT2	EU	R7UT-2	CO	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(1) § 117.1210(b) § 117.1210(b)(1)(A)	No person shall allow the discharge into the atmosphere from any unit subject to the NO <sub>x</sub> emission specifications specified in subsection (a) of this section, carbon monoxide (CO) emissions in excess of 400 parts per million by volume (ppmv) at 3.0% oxygen (O <sub>2</sub> ), dry, or alternatively, 0.31 lb/MMBtu heat input for oil-fired stationary gas turbines.	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(b) § 117.1240(i) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements  (30 TAC § 122.144)	Reporting Requirements  (30 TAC § 122.145)
GRPGT2	EU	R7UT-2	NO <sub>x</sub>	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(a)(3) [G]§ 117.1203(c) § 117.1210(c)(3) § 117.1220(a) § 117.1220(b) [G]§ 117.1220(c) § 117.1220(d) § 117.1220(e) § 117.1220(i) § 117.1220(j) § 117.1220(k) § 117.1220(l) § 117.1220(m) § 117.1240(l) § 117.1240(l)(2) § 117.1240(o) § 117.1240(o)(3)	Emission specifications for the Mass Emission Cap and Trade Program. The owner or operator of each stationary gas turbine (including duct burners used in turbine exhaust ducts), shall ensure that emissions of nitrogen oxides (NO <sub>x</sub> ) do not exceed 0.032, in lb/MMBtu heat input, on the basis of daily and 30-day averaging periods as specified in §117.1220 of this title, and as specified in the mass emissions cap and trade program of Chapter 101, Subchapter H, Division 3 of this title.	§ 117.1220(d) § 117.1220(e)(2) § 117.1220(h) § 117.1220(k) § 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(a) § 117.1240(e) § 117.1240(e)(1) § 117.1240(i) § 117.1240(n) § 117.1240(o)(1) [G]§ 117.1240(o)(2)	§ 117.1220(f) § 117.1245(a) [G]§ 117.1245(e)	[G]§ 117.1203(c) § 117.1220(g) § 117.1235(b) § 117.1245(b) § 117.1245(b)(1) [G]§ 117.1254(b) § 117.1254(c) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRPGT2-LOV	EP	R1111-2	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRPGTSTK	EU	R1111-1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRPTANK1	EU	R5112-1	VOC	30 TAC Chapter	§ 115.111(a)(1)	Except as provided in §	[G]§ 115.117	§ 115.118(a)(1)	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements  (30 TAC § 122.144)	Reporting Requirements  (30 TAC § 122.145)
				115, Storage of VOCs		115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.		§ 115.118(a)(5) § 115.118(a)(7)	
GRPTANK2	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPTANK3	EU	R5112-1	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GT1	EU	R7UT-1	CO	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(b)(1) § 117.1210(b) § 117.1210(b)(1)(A)	No person shall allow the discharge into the atmosphere from any unit subject to the NO <sub>x</sub> emission specifications specified in subsection (a) of this section, carbon monoxide (CO) emissions in excess of 400 parts per million by volume (ppmv) at 3.0% oxygen (O <sub>2</sub> ), dry, or alternatively, 0.30 lb/MMBtu heat input for gas-fired stationary gas turbines.	§ 117.1235(a) § 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(b) § 117.1240(i) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.1245(a) [G]§ 117.1245(e)	§ 117.1235(b) § 117.1245(b) § 117.1245(b)(1) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GT1	EU	R7UT-1	NO <sub>x</sub>	30 TAC Chapter 117, Utility Electric Generation	§ 117.1210(a)(3) [G]§ 117.1203(c) § 117.1210(c)(3) § 117.1220(a) § 117.1220(b)	Emission specifications for the Mass Emission Cap and Trade Program. The owner or operator of each stationary gas turbine	§ 117.1220(d) § 117.1220(e)(2) § 117.1220(h) § 117.1220(k) § 117.1235(a)	§ 117.1220(f) § 117.1245(a) [G]§ 117.1245(e)	[G]§ 117.1203(c) § 117.1220(g) § 117.1235(b) § 117.1245(b) § 117.1245(b)(1)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements  (30 TAC § 122.144)	Reporting Requirements  (30 TAC § 122.145)
					[G]§ 117.1220(c) § 117.1220(d) § 117.1220(e) § 117.1220(i) § 117.1220(j) § 117.1220(k) § 117.1220(l) § 117.1220(m) § 117.1240(l) § 117.1240(l)(2) § 117.1240(o) § 117.1240(o)(3)	(including duct burners used in turbine exhaust ducts), shall ensure that emissions of nitrogen oxides (NO <sub>x</sub> ) do not exceed 0.032, in lb/MMBtu heat input, on the basis of daily and 30-day averaging periods as specified in §117.1220 of this title, and as specified in the mass emissions cap and trade program of Chapter 101, Subchapter H, Division 3 of this title.	§ 117.1235(a)(1) § 117.1235(a)(3) § 117.1240(a) § 117.1240(e) § 117.1240(e)(1) § 117.1240(i) § 117.1240(n) § 117.1240(o)(1) [G]§ 117.1240(o)(2)		[G]§ 117.1254(b) § 117.1254(c) § 117.1256 § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GT1-LOV	EP	R1111-2	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GT1C	EP	R1111-2	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GT1C	EU	63ZZZZ-01	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	requirements as specified in Table 2c.1.a-c.	Table6.9.a.ii		
GT1E	EP	R1111-2	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GT1E	EU	63ZZZZ-01	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6602-Table2c.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(f)(1) § 63.6640(f)(2) § 63.6640(f)(2)(i) § 63.6640(f)(3)	For each existing emergency stationary CI RICE and black start stationary CI RICE, located at a major source, you must comply with the requirements as specified in Table 2c.1.a-c.	§ 63.6625(f) § 63.6625(i) § 63.6640(a) § 63.6640(a)-Table6.9.a.i § 63.6640(a)-Table6.9.a.ii	§ 63.6625(i) § 63.6655(e) § 63.6655(f) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(e) § 63.6650(f)
MCT3	EP	R1111-1	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
S1	EU	R5131-1	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None



### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						psia obtained from any equipment is exempt from §115.132(a).			
T120	EU	R5112-2	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.112(e)(1)	No person shall place, store, or hold VOC in any storage tank unless the storage tank is capable of maintaining working pressure sufficient at all times to prevent any vapor or gas loss to the atmosphere or is in compliance with the control requirements specified in Table 1 of this paragraph for VOC other than crude oil and condensate or Table 2 of subsection (a)(1) of this paragraph for crude oil and condensate.	[G]§ 115.117 ** See Periodic Monitoring Summary	§ 115.118(a)(5) § 115.118(a)(7)	None
THWUNLOAD	EU	R5212-1	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
U3ST-LOV	EP	R1111-2	Opacity	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
U4ST-LOV	EP	R1111-2	Opacity	30 TAC Chapter 111, Visible	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not	[G]§ 111.111(a)(1)(F) ** See Periodic	None	None

### Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Emissions		exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	Monitoring Summary		

## **Additional Monitoring Requirements**

<b>Periodic Monitoring Summary .....</b>	<b>34</b>
--	-----------

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPGT1-LOV	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-2
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Opacity greater than 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. The source must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observation cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. Documentation of all observations shall be maintained. If visible emissions are observed, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPGT2-LOV	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-2
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Opacity greater than 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. The source must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observation cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. Documentation of all observations shall be maintained. If visible emissions are observed, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPGTSTK	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: N/A	
Deviation Limit: Any opacity readings that are above 15% averaged over a six-minute period shall be reported as a deviation.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GT1-LOV	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-2
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Opacity greater than 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. The source must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observation cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. Documentation of all observations shall be maintained. If visible emissions are observed, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GT1C	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-2
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: N/A	
Deviation Limit: Opacity greater than 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	



### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GT1E	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-2
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: N/A	
Deviation Limit: Opacity greater than 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: MCT3	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-1
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Opacity greater than 15% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. The source must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observation cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. Documentation of all observations shall be maintained. If visible emissions are observed, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: T120	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Liquid Level	
Minimum Frequency: At the end of each unloading operation	
Averaging Period: N/A	
Deviation Limit: Liquid level below the fill pipe level.	
<p>Periodic Monitoring Text: Regardless of the location of the fill pipe, the fill pipe must be submerged at all times. Soundings shall be made and recorded to determine the depth of the liquid. The soundings will be compared to the depth of the fill pipe. It shall be considered and reported as a deviation any time the liquid level falls below the fill pipe level.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: T120	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Storage of VOCs	SOP Index No.: R5112-2
Pollutant: VOC	Main Standard: § 115.112(e)(1)
Monitoring Information	
Indicator: Structural Integrity of the Pipe	
Minimum Frequency: Emptied and degassed	
Averaging Period: N/A	
Deviation Limit: Structural integrity of the pipe.	
Periodic Monitoring Text: Inspect to determine the structural integrity of the fill pipe and record each time the storage vessel is emptied and degassed. If the structural integrity of the fill pipe is in question, repairs shall be made before the storage vessel is refilled. It shall be considered and reported as a deviation if the repairs are not completed prior to refilling the storage vessel.	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: U3ST-LOV	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-2
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Opacity greater than 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. The source must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observation cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. Documentation of all observations shall be maintained. If visible emissions are observed, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

### Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: U4ST-LOV	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-2
Pollutant: Opacity	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: Annually	
Averaging Period: N/A	
Deviation Limit: Opacity greater than 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. The source must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observation cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. Documentation of all observations shall be maintained. If visible emissions are observed, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

**Permit Shield**

**Permit Shield ..... 46**

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
A-108	N/A	30 TAC Chapter 115, Storage of VOCs	Tank capacity is less than 1,000 gallons.
DG-1	N/A	30 TAC Chapter 115, Degreasing Processes	Solvent used has a vapor pressure less than 0.6 psia at 100 °F with a drain area less than 16 in <sup>2</sup> , and the waste solvent is disposed of properly in enclosed containers.
DG-2	N/A	30 TAC Chapter 115, Degreasing Processes	Solvent used has a vapor pressure less than 0.6 psia at 100 °F with a drain area less than 16 in <sup>2</sup> , and the waste solvent is disposed of properly in enclosed containers.
GH1	N/A	30 TAC Chapter 112, Sulfur Compounds	Gas pipeline heater does not fire liquid fuel.
GH1S	N/A	30 TAC Chapter 115, Vent Gas Controls	This exhaust steam originates from a combustion unit that is not being used as a control device for a vent gas stream subject to this Division of Chapter 115.
GRPGT1	GT31, GT32, GT33, GT34, GT41, GT42, GT43, GT44	40 CFR Part 60, Subpart GG	Combustion turbines commenced construction, modification, or reconstruction prior to October 3, 1977.
GRPGT1	GT31, GT32, GT33, GT34, GT41, GT42, GT43, GT44	40 CFR Part 60, Subpart KKKK	Combustion turbines commenced construction, modification, or reconstruction prior to February 18, 2005.
GRPGT1	GT31, GT32, GT33, GT34, GT41, GT42, GT43, GT44	40 CFR Part 63, Subpart YYYY	Combustion turbines commenced construction, modification, or reconstruction prior to January 14, 2003.
GRPGT1-LOV	GT31-LOV, GT32-LOV, GT33-LOV, GT34-LOV, GT41-LOV, GT42-LOV, GT43-LOV, GT44-LOV	30 TAC Chapter 115, Vent Gas Controls	Vents do not emit VOC.
GRPGT2	GT51, GT52, GT53, GT54, GT55,	40 CFR Part 60, Subpart GG	Combustion turbines commenced construction,



### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
	GT56		modification, or reconstruction prior to October 3, 1977.
GRPGT2	GT51, GT52, GT53, GT54, GT55, GT56	40 CFR Part 60, Subpart KKKK	Combustion turbines commenced construction, modification, or reconstruction prior to February 18, 2005.
GRPGT2	GT51, GT52, GT53, GT54, GT55, GT56	40 CFR Part 63, Subpart YYYY	Combustion turbines commenced construction, modification, or reconstruction prior to January 14, 2003.
GRPGT2-LOV	GT51-LOV, GT52-LOV, GT53-LOV, GT54-LOV, GT55-LOV, GT56-LOV	30 TAC Chapter 115, Vent Gas Controls	Vents do not emit VOC.
GRPGTSTK	THWGT1, THWGT31, THWGT32, THWGT33, THWGT34, THWGT41, THWGT42, THWGT43, THWGT44, THWGT51, THWGT52, THWGT53, THWGT54, THWGT55, THWGT56	30 TAC Chapter 115, Vent Gas Controls	Not being used as a control device for any vent gas stream and originates from a non-combustion source.
GRPTANK2	A-105-1, A-105-2, A-106-1, A-106-2, A-132, A-133, A-134, A-135, A-136, A-137, A-138, A-139	40 CFR Part 60, Subpart K	Tank capacity is less than 40,000 gallons.
GRPTANK3	A-206, B-207	40 CFR Part 60, Subpart Ka	Tank capacity is less than 40,000 gallons.
GT1	N/A	40 CFR Part 60, Subpart GG	Combustion turbines commenced construction, modification, or reconstruction prior to October 3, 1977.
GT1	N/A	40 CFR Part 60, Subpart KKKK	Combustion turbines commenced construction, modification, or reconstruction prior to February 18, 2005.
GT1	N/A	40 CFR Part 63, Subpart YYYY	Combustion turbines commenced construction, modification, or reconstruction prior to January

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
			14, 2003.
GT1-LOV	N/A	30 TAC Chapter 115, Vent Gas Controls	Vent does not emit VOC.
GT1C	N/A	30 TAC Chapter 117, Commercial	30 TAC Chapter 117, Subchapter B does not apply to electric utility sources that are subject to Subchapter C.
GT1C	N/A	40 CFR Part 60, Subpart IIII	The source commenced construction, modification, or reconstruction prior to July 11, 2005.
GT1C	N/A	40 CFR Part 60, Subpart JJJJ	Engine is not a spark ignition internal combustion engine.
GT1E	N/A	30 TAC Chapter 117, Commercial	30 TAC Chapter 117, Subchapter B does not apply to electric utility sources that are subject to Subchapter C.
GT1E	N/A	40 CFR Part 60, Subpart IIII	The source commenced construction, modification, or reconstruction prior to July 11, 2005.
GT1E	N/A	40 CFR Part 60, Subpart JJJJ	Engine is not a spark ignition internal combustion engine.
MCT3	N/A	40 CFR Part 63, Subpart Q	This source does not operate with chromium based water treatment chemicals.
NGFUG	N/A	40 CFR Part 61, Subpart J	Fugitive piping components do not operate in benzene service as defined in 40 CFR §61.111.
NGFUG	N/A	40 CFR Part 61, Subpart V	These sources do not operate in volatile hazardous air pollutant (VHAP) service.
NGFUG	N/A	40 CFR Part 63, Subpart H	Fugitive piping components do not operate in organic hazardous air pollutant service 300

### Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit / Group / Process ID No.	Group / Inclusive Units	Regulation	Basis of Determination
			hours or more during a calendar year within a source subject to the provisions of a specific subpart in 40 CFR Part 63 that references 40 CFR Part 63, Subpart H.
T120	N/A	40 CFR Part 60, Subpart Kb	Storage capacity less than 75 cubic meters
U3ST-LOV	N/A	30 TAC Chapter 115, Vent Gas Controls	Vent does not emit VOC.
U4ST-LOV	N/A	30 TAC Chapter 115, Vent Gas Controls	Vent does not emit VOC.

**New Source Review Authorization References**

<b>New Source Review Authorization References .....</b>	<b>51</b>
<b>New Source Review Authorization References by Emission Unit .....</b>	<b>52</b>

### New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

<b>Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.</b>	
Authorization No.: 2094	Issuance Date: 09/22/2020
Authorization No.: 21592	Issuance Date: 09/28/2020
Authorization No.: 45578	Issuance Date: 07/13/2012
Authorization No.: 74765	Issuance Date: 09/26/2014
Authorization No.: 77520	Issuance Date: 07/13/2015
Authorization No.: 79786	Issuance Date: 08/03/2016
Authorization No.: 80979	Issuance Date: 08/03/2016
Authorization No.: 80980	Issuance Date: 08/03/2016
Authorization No.: 86198	Issuance Date: 04/05/2018
Authorization No.: 86896	Issuance Date: 04/06/2018
<b>Permits By Rule (30 TAC Chapter 106) for the Application Area</b>	
Number: 5	Version No./Date: 06/07/1996
Number: 8	Version No./Date: 06/07/1996
Number: 34	Version No./Date: 06/07/1996
Number: 39	Version No./Date: 06/07/1996
Number: 40	Version No./Date: 06/07/1996
Number: 51	Version No./Date: 06/07/1996
Number: 53	Version No./Date: 06/07/1996
Number: 61	Version No./Date: 06/07/1996
Number: 66	Version No./Date: 09/12/1989
Number: 102	Version No./Date: 06/07/1996
Number: 103	Version No./Date: 06/07/1996
Number: 106.183	Version No./Date: 06/18/1997
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.352	Version No./Date: 09/04/2000
Number: 106.371	Version No./Date: 03/14/1997
Number: 106.511	Version No./Date: 03/14/1997
Number: 106.532	Version No./Date: 03/14/1997
Number: 107	Version No./Date: 08/30/1988
Number: 111	Version No./Date: 05/04/1994

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
A-105-1	UNIT #4 LUBE OIL RESERVOIR	51/06/07/1996
A-105-2	UNIT #3 LUBE OIL RESERVOIR	51/06/07/1996
A-106-1	G.T. 51-56 CLEAN LUBE OIL TANKS	51/06/07/1996
A-106-2	G.T. 51-56 DIRTY LUBE OIL TANKS	51/06/07/1996
A-107-1	G.T. 31-44 CLEAN LUBE OIL TANK	51/06/07/1996
A-107-2	G.T. 31-44 DIRTY LUBE OIL TANK	51/06/07/1996
A-108	WESTINGHOUSE GAS TURBINE DIESEL TANK	51/06/07/1996
A-123	UNIT 3 LUBE OIL TANK	51/06/07/1996
A-124	UNIT 4 LUBE OIL TANK	51/06/07/1996
A-125	G.T. 31 LUBE OIL RESERVOIR	51/06/07/1996
A-126	G.T. 32 LUBE OIL RESERVOIR	51/06/07/1996
A-127	G.T. 33 LUBE OIL RESERVOIR	51/06/07/1996
A-128	G.T. 34 LUBE OIL RESERVOIR	51/06/07/1996
A-129	G.T. 41 LUBE OIL RESERVOIR	51/06/07/1996
A-130	G.T. 42 LUBE OIL RESERVOIR	51/06/07/1996
A-131	G.T. 43 LUBE OIL RESERVOIR	51/06/07/1996
A-132	G.T. 44 LUBE OIL RESERVOIR	51/06/07/1996
A-133	G.T. 51 LUBE OIL RESERVOIR	51/06/07/1996
A-134	G.T. 52 LUBE OIL RESERVOIR	51/06/07/1996
A-135	G.T. 53 LUBE OIL RESERVOIR	51/06/07/1996
A-136	G.T. 54 LUBE OIL RESERVOIR	51/06/07/1996

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
A-137	G.T. 55 LUBE OIL RESERVOIR	51/06/07/1996
A-138	G.T. 56 LUBE OIL RESERVOIR	51/06/07/1996
A-139	WESTINGHOUSE GT LUBE OIL RESERVOIR	51/06/07/1996
A-206	TRICELLERATOR	51/06/07/1996
B-207	API WASTE OIL TANK	51/06/07/1996
DG-1	NORTH END MAIN SHOP DEGREASER	107/08/30/1988
DG-2	SOUTH END MAIN SHOP DEGREASER	107/08/30/1988
GH1	GAS PIPELINE HEATER	106.183/06/18/1997
GH1S	GAS PIPELINE HEATER STACK	106.183/06/18/1997
GT1	GAS TURBINE-EMERGENCY	45578
GT1-LOV	GAS TURBINE EMERGENCY LUBE OIL VENT	45578
GT1C	CRANKING DIESEL ENGINE	5/06/07/1996
GT1E	EMERGENCY DIESEL ENGINE	5/06/07/1996
GT31	GAS TURBINE NO. 31	21592, 80979
GT31-LOV	GAS TURBINE NO. 31 LUBE OIL VENT	21592
GT32	GAS TURBINE NO. 32	21592, 86896
GT32-LOV	GAS TURBINE NO. 32 LUBE OIL VENT	21592
GT33	GAS TURBINE NO. 33	21592, 74765
GT33-LOV	GAS TURBINE NO. 33 LUBE OIL VENT	21592
GT34	GAS TURBINE NO. 34	21592, 74765
GT34-LOV	GAS TURBINE NO. 34 LUBE OIL VENT	21592

### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
GT41	GAS TURBINE NO. 41	21592, 77520
GT41-LOV	GAS TURBINE NO. 41 LUBE OIL VENT	21592
GT42	GAS TURBINE NO. 42	21592, 79786
GT42-LOV	GAS TURBINE NO. 42 LUBE OIL VENT	21592
GT43	GAS TURBINE NO. 43	21592, 80980
GT43-LOV	GAS TURBINE NO. 43 LUBE OIL VENT	21592
GT44	GAS TURBINE NO. 44	21592, 86198
GT44-LOV	GAS TURBINE NO. 44 LUBE OIL VENT	21592
GT51	GAS TURBINE NO. 51	2094
GT51-LOV	GAS TURBINE NO. 51 LUBE OIL VENT	2094
GT52	GAS TURBINE NO. 52	2094
GT52-LOV	GAS TURBINE NO. 52 LUBE OIL VENT	2094
GT53	GAS TURBINE NO. 53	2094
GT53-LOV	GAS TURBINE NO. 53 LUBE OIL VENT	2094
GT54	GAS TURBINE NO. 54	2094
GT54-LOV	GAS TURBINE NO. 54 LUBE OIL VENT	2094
GT55	GAS TURBINE NO. 55	2094
GT55-LOV	GAS TURBINE NO. 55 LUBE OIL VENT	2094
GT56	GAS TURBINE NO. 56	2094
GT56-LOV	GAS TURBINE NO. 56 LUBE OIL VENT	2094
MCT3	UNIT 3/4 COOLING TOWER	8/06/07/1996



### New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization**
NGFUG	NATURAL GAS PIPING FUGITIVES	2094
S1	OILY WASTE TREATMENT SYSTEM SEPARATOR	61/06/07/1996
T120	NATURAL GAS LIQUID DISTILLATE TANK - GT44	66/09/12/1989
THWGT1	GAS TURBINE NO. 1 STACK	45578
THWGT31	GAS TURBINE STACKS NO. 31	21592, 80979
THWGT32	GAS TURBINE STACKS NO. 32	21592, 86896
THWGT33	GAS TURBINE STACKS NO. 33	21592, 74765
THWGT34	GAS TURBINE STACKS NO. 34	21592, 74765
THWGT41	GAS TURBINE STACKS NO. 41	21592, 77520
THWGT42	GAS TURBINE STACKS NO. 42	21592, 79786
THWGT43	GAS TURBINE STACKS NO. 43	21592, 80980
THWGT44	GAS TURBINE STACKS NO. 44	21592, 86198
THWGT51	GAS TURBINE STACKS NO. 51	2094
THWGT52	GAS TURBINE STACKS NO. 52	2094
THWGT53	GAS TURBINE STACKS NO. 53	2094
THWGT54	GAS TURBINE STACKS NO. 54	2094
THWGT55	GAS TURBINE STACKS NO. 55	2094
THWGT56	GAS TURBINE STACKS NO. 56	2094
THWUNLOAD	T.H. WHARTON UNLOADING OPERATIONS	51/06/07/1996, 53/06/07/1996
U3ST-LOV	UNIT 3 STEAM TURBINE LUBE OIL VENT	21592
U4ST-LOV	UNIT 4 STEAM TURBINE LUBE OIL VENT	21592

\*\*This column may include Permit by Rule (PBR) numbers and version dates, PBR Registration numbers in brackets, Standard Permit Registration numbers, Minor NSR permit numbers, and Major NSR permit numbers.

**Appendix A**

**Acronym List ..... 58**

## Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H <sub>2</sub> S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO <sub>x</sub>	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
SIP	state implementation plan
SO <sub>2</sub>	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound